

36" MANHOLE WATER  
TIGHT LID, TRAFFIC RATED  
AS REQUIRED.

36"

GRADE

2" THREADED CAP

WELL  
CASING

APPROVED  
WELL CAP,  
WELDED  
OR  
RESILIENT  
SEAL 6"  
BELOW  
LID.

5" THICK  
CONCRETE  
VAULT

24"

2" DRAIN PIPE EXTENDED TO  
AN APPROVED DRAINFIELD.

PREVIOUSLY  
ABANDONED WELL  
CASING



CITY OF COEUR D'ALENE STANDARD DRAWING

# MONITORING WELL MODIFICATIONS

APPROVED BY:

*Chris Booley*  
CITY ENGINEER, PE 10804

10/1/24  
DATE:

DWG NO.

W-28