



- FLANGED PIPE
- FLANGED OS&Y GATE VALVE
- FLANGED NIPPLE (LENGTH AS REQ'D)
- ROMAC FCA501 STYLE COUPLING
- TURBO-METER (U.S. GALLONS) BADGER W/ RADIO READ SYSTEM W/ 20' WIRE LEAD AND ORION MXU
- STRAINER
- FLANGED OS&Y GATE VALVE
- FLANGED PIPE
- LADDER

NO BYPASS REQUIRED FOR IRRIGATION INSTALLATION

SEE METER VAULT DETAIL W-17
USE 1914 SERIES WILBERT VAULT

FLANGED PIPE, 4" MINIMUM, WILL BE RESTRAINED TO LAST MECHANICAL JOINT AT TEE. DO NOT USE VAULT WALL AS THRUST BEARING SURFACE.

PLAN VIEW

NOTES:

1. GATE VALVE TO BE INSTALLED AT HOT TAP TO WATER MAIN
2. 3" OR LARGER METER IN VAULT WILL BE RADIO READ



CITY OF COEUR D'ALENE STANDARD DRAWING
**4" & LARGER SERVICE SETTING
SETTING IRRIGATION VAULT**

APPROVED BY:
Chris Boddy
CITY ENGINEER, PE 10604
DATE: 10/1/24
DWG NO. W-16