


THRUST BLOCK BEARING AREA



NOTES

1. Based on 150 psi test pressure and a soil bearing pressure of 1500psf
2. For conditions not covered by these curves, special thrust blocks must be designed and approved.
3. Ecology blocking may be used with prior approval from the City Engineer and/or the Superintendent for mains 12" and less in size.
4. The Design Engineer shall provide thrust bearing area calculations using 1500psf as the desired standard prior to block approval.



CITY OF COEUR D'ALENE STANDARD DRAWING

***THRUST BLOCK
BEARING AREA***

APPROVED BY:

Chris Bosley 10/1/24
CITY ENGINEER, PE 10804 DATE:

DWG NO.

W-10